

Test Name: Sound Measurement of the Water Alarm Gong

Test Instruction Code: ITE/LB.I-24

Test purpose: Ensuring that the sound pitch (frequency) of the water alarm gong is acceptable at certain distances.

Applicability domain: Water Alarm Gong

Standard number: (FM Standard)

Test method: After turning on the water alarm gong system, the sound pitch (frequency) of the alarm sound is measured from a distance of 3 meters. The observed sound frequency shall be within the allowable interval as specified in the standard.

نام آزمون: صوت سنجی زنگ هشدار آبی

کد دستورالعمل آزمون: ITE/LB.I-24

هدف از آزمون: اطمینان از میزان فرکانس صدای قابل پذیرش زنگ هشدار آبی در فاصله تعریف شده است.

دامنه کاربرد: زنگ هشدار آبی

شماره استاندارد: (FM Standard)

روش آزمون: پس از روشن نمودن سیستم زنگ هشدار آبی، میزان فرکانس صدا را در فاصله سه متری از سیستم اندازه گیری می نمایم. مقدار مشاهده شده نباید خارج از محدوده مجاز در استاندارد باشد.



آزمون صوت سنجی زنگ هشدار آبی

Sound measurement of the water alarm gong test

