

Test Name: Measuring the Nozzle Water Drop

Test Instruction Code: ITE/LB.I-23

Test purpose: Ensuring the monitor water at different ranges.

Applicability domain: All Nozzles.

Standard number: Imen Tiar Engineering Factory Standard.

Test method: After adjusting the vertical angle of the monitor, the water drop quantity from different ranges shall be measured as specified in the instructions and shall be compared to the requirements of the customer. The measured values shall be within the allowable intervals.


نام آزمون: اندازه گیری میزان ریزش آب از نازل

کد دستورالعمل آزمون: ITE/LB.I-23

هدف از آزمون: اطمینان از میزان ریزش آب مانیتور در فواصل مختلف.

دامنه کاربرد: کلیه نازل ها

شماره استاندارد: استاندارد کارخانه ای شرکت مهندسی ایمن تیار
روش آزمون: پس از تنظیم زاویه عمودی مانیتور، طبق دستورالعمل مربوطه، میزان ریزش آب را در فواصل تعریف شده اندازه گیری و با الزام مشتری مقایسه می نمایم. مقدار اندازه گیری شده می بایست در محدوده اعلام شده باشد.



آزمون اندازه گیری میزان ریزش آب از نازل
Measuring the nozzle water drop test

